

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 109

Dated: 17/04/2024

It is certified that an inspection team headed by B. Rangaswamy, AEE, R.W.S. Hassan

(Name of Officers with designation) from Millennium World School, PHED

inspected the 08/04/2024

(Name & Address of the school) on MINS, Hassan (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. — dated 17/04/2024

of — (PHED Lab) certified that the

MINS Hassan (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till —

Signature with Seal: [Signature] Assistant Executive Engineer
Name: Rural Drinking Water and
Designation: Sanitation Department,
Name & Address of the Office / Department: Hassan Sub-Division, Hassan-573-201

To Millennium World School
#36 Chikkakondagale Koppale Tejvar Hassan,
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



ಗ್ರಾಮೀಣ ಕುಡಿಯುವ ನೀರು ಮತ್ತು ನೈರ್ಮಲ್ಯ ಇಲಾಖೆ
ಜಿಲ್ಲಾ ಕುಡಿಯುವ ನೀರು ಪರೀಕ್ಷಾ ಪ್ರಯೋಗಾಲಯ, ಹಾಸನ

ಕಾರ್ಯಪಾಲಕ ಅಧ್ಯಯಂಕರವರ ಕಛೇರಿ, ಗ್ರಾಮೀಣ
ಕುಡಿಯುವ ನೀರು ಮತ್ತು ನೈರ್ಮಲ್ಯ ಇಲಾಖೆ,
ಹಾಸನ ವಿಭಾಗ, ಹಾಸನ 573201

eerdwsd.hsn@gmail.com
rdwsd.wqmssp.hassanlab@gmail.com
Phone No.08172-261640

WATER SAMPLE TEST REPORT

1.District :	Hassan	5.Sample collection date:	08.04.2024
2.Taluk:	Hassan	6.Sample recieved date:	08.04.2024
3.Village:	Chikkakondagala	7.Source:	Bore Well
4.Grama Panchayath:	Tejur	8.Name and address:	Millennium World School, Chikkakondagola Village, Tejur GP, Hassan.

Sl.No	Characteristic	Requirement (Acceptable limit)	Permissible Limit in the Absence of Alternate Source	Method of Test,Ref to	Result
1	Colour,Hazen units	5	15	IS 3025(Part-4):2021	1
2	Odour	Agreeable	Agreeable	IS 3025(Part -5 &6):2018	Agreeable
3	Taste	Agreeable	Agreeable	IS 3025 (Part 8):1983 (RA 2017)	Agreeable
4	Ph, Value	6.5-8.5	No Relaxation	IS 3025 (Part 11):2022	8.05
5	Turbidity, NTU	1	5	IS 3025 (Part 10):1984 (RA 2017)	1
6	Total Dissolved solid, mg/l	500	2000	IS 3025 (Part 16):1984 (RA 2017)	502
7	Conductivity us/cm	-	-	IS 3025 (Part 14):2019	754
8	Calcium(as Ca) mg/l	75	200	IS 3025 (Part 40):1991 (RA 2019)	43.27
9	Chloride (as Cl) mg/l	250	1000	IS 3025 (Part 32):1988 (RA 2019)	37.98
10	Fluoride (as F)mg/l	1	1.5	APHA 23rd Edition	0.14
11	Iron (as Fe)mg/l	1	No Relaxation	IS 3025 (Part 53):2003 (RA 2019)	0.19
12	Magnesium (as Mg) mg/l	30	100	IS 3025 (Part 46):1994 (RA 2019)	19.44
13	Nitrate (as NO ₃) mg/l	45	No Relaxation	APHA 23rd Edition	14.4
14	Sulphate (as SO ₄) mg/l	200	400	IS 3025 (Part 24/sec 1):2022	20.9
15	Total Alkalinity mg/l	200	600	IS 3025 (Part 23):1986 (RA 2019)	240
16	Total Hardness (as CaCO ₃)mg/l	200	600	IS 3025 (Part 21):2009 (RA 2019)	189.69
17	Total Arsenic (as As) mg/l	0.01	No Relaxation	IS 3025 (Part 37)	-

Inference:The analyzed values for the above parameters are within the limit as per IS-10500:2012.

Date: 17.04.2024
Place: Hassan

Praveen A H
Chemist
District Water Testing Laboratory
R.D.W.& S D Hassan.

For MILLENNIUM WORLD SCHOOL
Smitha T Muthy
CHAIRMAN

For Millennium World School
Edhar Hassan
Director Principal